


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

The most updated information on this Certificate of Listing is available online at pld.iapmo.org

Effective Date: April 2018 Void After: April 2019

Product: Rainwater Harvesting Tanks File No. 11089

Issued To: XERXES CORPORATION
7901 XERXES AVENUE SOUTH
SUITE 201
BLOOMINGTON, MN 55431

Identification: Each tank shall be clearly and permanently marked with the manufacturer's name and/or registered trademark, model or serial number, working liquid volume, date (i.e., month and year), date code or identifier traceable to the date of manufacture, maximum design load and maximum burial depth for which the tank is designed, when applicable. Accesses not suitable for human entry shall be mark with "DO NOT ENTER". Accesses intended for human entry shall be marked "CONFINED SPACE. FOLLOW APPROPRIATE PROCEDURES BEFORE ENTRY". Markings shall appear on permanently-affixed metal plates, etching, mechanical stamping, stamping with a permanent (non-water-soluble) ink, or molding in. Adhesive labels that comply with UL 969 shall also be considered permanent when placed on a surface that is not normally submerged in water. Permanent markings shall be adequately protected from corrosion so as to remain legible over the life of the tank. The product shall also bear the UPC® certification mark adjacent to product markings. Rainwater harvesting tanks with liners shall also have markings indicating that the tank has a liner, the thickness of the liner, and the material of the liner.

Characteristics: Rainwater harvesting tanks made of concrete, fiber-reinforced polyester, steel, thermoplastics, wood, or vinyl-coated polyester. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)

Products are in compliance with the following standard(s):

IAPMO/ANSI Z1002-2014

MODELS:

Model No.
1000 RWHT
2000 RWHT
3000 RWHT
4000 RWHT
5000 RWHT
6000 RWHT
7000 RWHT
8000 RWHT
9000 RWHT
10000 RWHT
11000 RWHT
12000 RWHT
13000 RWHT
14000 RWHT
15000 RWHT
16000 RWHT
17000 RWHT
18000 RWHT
19000 RWHT
20000 RWHT
21000 RWHT
22000 RWHT
23000 RWHT
24000 RWHT
25000 RWHT
26000 RWHT
27000 RWHT
28000 RWHT
29000 RWHT
30000 RWHT
31000 RWHT
32000 RWHT
33000 RWHT
34000 RWHT
35000 RWHT
36000 RWHT
37000 RWHT
38000 RWHT
39000 RWHT
40000 RWHT
41000 RWHT
42000 RWHT
43000 RWHT
44000 RWHT
45000 RWHT
46000 RWHT
47000 RWHT
48000 RWHT
49000 RWHT
50000 RWHT



Print Certificate