


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

The most updated information on this Certificate of Listing is available online at pld.iapmo.org

Effective Date: January 2019

Void After: January 2024

Product: Prefabricated Gravity Grease Interceptors

File No. 5163

Issued To: XERXES CORPORATION
7901 XERXES AVENUE SOUTH
SUITE 201
BLOOMINGTON, MN 55431

Identification: Prefabricated gravity grease interceptors shall be permanently and legibly marked with the manufacturer's name and/or trademark, model number, working liquid volume (expressed at least in gallons), date (i.e. month and year), date code, or identifier traceable to the date of manufacture, maximum design load, maximum burial depth, inlet, and outlet. The markings shall be applied on permanently-affixed metal plates, etched, mechanically stamped, stamped with permanent (non-water-soluble) ink, or molded. Adhesive labels that comply with UL 969 shall also be considered permanent when placed on a surface that is not normally submerged in water. The product shall also bear the UPC® certification mark.

Characteristics: Prefabricated gravity grease interceptors made of concrete, fiber reinforced polyester (FRP), thermoplastic, or steel. Grease interceptors with at least two (2) compartments designed to remove grease from effluent and to retain grease until accumulations can be removed by pumping the interceptor.

Grease interceptors shall have a minimum size of 20 inches of manhole over the inlet and outlet compartments. It is recommended that a sample box be located at the outlet end of all grease interceptors so that the administrative authorities can periodically sample effluent quality.

To be installed in accordance with the manufacturer's instructions and the requirements of the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)
International Plumbing Code (IPC®)

Products are in compliance with the following standard(s):

IAPMO/ANSI Z1001-2016

MODELS:

4' Diameter Tanks
GI-4-500-UPC

GI-4-750-UPC
GI-4-825-UPC
GI-4-1000-UPC
GI-4-1200-UPC
GI-4-1250-UPC
GI-4-1500-UPC
GI-4-500-UPC-AST
GI-4-750-UPC-AST
GI-4-825-UPC-AST
GI-4-1000-UPC-AST
GI-4-1200-UPC-AST
GI-4-1250-UPC-AST
GI-4-1500-UPC-AST

5' Diameter Tanks

RST-II 1,000
RST-II 1,500

6' Diameter Tanks

GI-6-2000-UPC
GI-6-2500-UPC
GI-6-3000-UPC
GI-6-3500-UPC
GI-6-4000-UPC
GI-6-4400-UPC
GI-6-5000-UPC
GI-6-6000-UPC
GI-6-7000-UPC
GI-6-2000-UPC-AST
GI-6-2500-UPC-AST
GI-6-3000-UPC-AST
GI-6-3500-UPC-AST
GI-6-4000-UPC-AST
GI-6-4400-UPC-AST
GI-6-5000-UPC-AST

8' Diameter Tanks

GI-8-4400-UPC
GI-8-5000-UPC
GI-8-6000-UPC
GI-8-6750-UPC
GI-8-7500-UPC
GI-8-8000-UPC
GI-8-9000-UPC
GI-8-10000-UPC
GI-8-11000-UPC
GI-8-12000-UPC

10' Diameter Tanks

GI-10-7500-UPC
GI-10-8750-UPC
GI-10-10000-UPC
GI-10-11000-UPC
GI-10-14000-UPC
GI-10-18750-UPC
GI-10-22250-UPC

This information was valid on 1/10/2019.